

Large Service Application (Greater than 2")
Queensbury Water Department
823 Corinth Road
Queensbury, New York 12804
Phone: 518-793-8866 Fax: 518-798-3320
www.queensbury.net

For Office Use Only
Account #: _____
Meter Size: _____

Location of Water Line: _____

Is large service to be used for domestic water? _____ Size of domestic water line: _____

Owner's Name: _____ Date: _____

Address: _____ Size of Service: _____

Contractor's Name: _____ Tax Map #: _____

Address: _____ Tapping Contractor: _____

Phone Number: _____ Phone Number: _____

Please Read Carefully

The applicant is responsible for all costs incurred to make the connection and install a water main from the existing main into the building. This installation must comply with the New York State Building Codes & Queensbury Water Design & Construction Standards.

- **Approved Plans:** Plans of proposed work should be submitted to and approved by the Queensbury Water Department prior to start of any construction. A stamped copy of the approved plans should be on the construction site at all times.
- **Greater than 2":** All water lines greater than 2" in diameter will be the customer's responsibility to maintain from the gate valve to the building.
- **Taps:** A tapping contractor approved by the Queensbury Water Department shall make all taps.
- **Water Department Control:** Operation of all curb valves, gate valves and hydrants under pressure shall be done by duly designated employees of the Water Department.
- **Inspections:** All installations of water mains and appurtenances must be inspected by the Water Department prior to backfilling. Inspections will be done during normal business hours. No inspections will be made after hours, holidays or weekends.
- **Testing & Disinfection:** All water mains will be pressure tested by the contractor and certified by his engineer. Certification will be supplied to the Water Department. Disinfection will be the responsibility of the contractor. The contractor and/or developer shall coordinate and schedule testing and disinfection with the Water Department.
- **Meters:** Occasionally, we receive a request from our customers to sell them a meter. The meters would typically be larger than 2". This is permitted with the following conditions: The meter is for use on a line connected to the Queensbury water system. The meter size and type has been approved by either the billing supervisor or water superintendent. The customer provides the water department with documentation that they would like us to order the meter for their use and that they will pay a specified cost at the time of receipt. This document should also indicate whether or not flanges or strainers should be included.

Signature

Date