FACTS ABOUT INSPECTIONS

The Fire Marshal's office conducts inspections periodically to assure compliance with NY State Fire Prevention and Building Code.

Self check help sheet -

- ✓ Exits and paths to exits must be maintained clear of obstructions and free of certain types of locks.
- ✓ Exit Signs must be illuminated. Test battery if backup is provided.
- ✓ Emergency Lights must function when the power is out. Battery backup must be provided and should be tested regularly.
- ✓ **Sprinkler Systems** require annual testing. Risers must be accessible and storage must be 18″ below sprinkler heads on a level plane.
- ✓ Electric Panels must not be obstructed. Proper circuit labeling should be in place. All circuits should be filled. No storage in these rooms.
- ✓ **Aisles** must be maintained clear of all obstructions.
- ✓ Fire Extinguishers must be hung and be clearly visible. Extinguishers require annual inspection by qualified service personnel.
- ✓ Fire Alarm Systems function and all components require annual inspection by qualified service personnel.

TOWN OF QUEENSBURY FIRE MARSHAL'S OFFICE

Phone: 518-761-8206 • Fax: 518-745-4437

firemarshal@queensbury.net • www.queensbury.net